NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO: NI016953.02
DATE: 07/08/2026
CERTIFICATION PROGRAM: Structural
COMPANY: United
CODE: 2779-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
United Window & Door Manufacturing **24-36 Fadem Road** **Springfield, New Jersey 07081**	**Series "3900"** **Vinyl Single Hung Window** Configuration: O/X Glazing: Insulated Glass (Annealed) Frame: W-1067mm(42") H-1372mm(54") Sash: W-991mm(39") H-657mm(25.88") DLO: W-927mm(36.50") H-597mm(23.50")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22	**Class R-PG50 1067 x 1372 (42 x 54)-H** **Design Pressure: ±2400 Pa (±50 psf)** **Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)**

Product Tested By: Molimo, LLC
Report No: 33129.01-106-12
Expiration Date: **May 31, 2030**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com