NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI017040.01**
DATE:	**07/09/2026**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Young Corp.**
CODE:	**3007-1**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Young Corporation of America, LLC, **dba DURABOLD** **4261 Communications Drive** **Norcross, GA 30093**	**Series "82-B"** **Vinyl Horizontal Sliding Window** Configuration: OX Glazing: Insulating Glass (Tempered) Frame: W-1829mm(72.01") H-1524mm(60") Sash: W-896mm(35.28") H-1471mm(57.91") DLO: W-841mm(33.11") H-1416mm(55.75")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	**Class LC-PG25 1829 x 1524 (72 x 60)-HS** **Design Pressure: ±1200 Pa (±25 psf)** **Water Penetration Resistance Test Pressure: 180 Pa (3.76 psf)**

Product Tested By: Intertek, PLC
Report No: 260420006SHF-001
Expiration Date: **May 31, 2030**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com