NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO: NI017047.01
DATE: 07/22/2026
CERTIFICATION PROGRAM: Structural
COMPANY: Robinson Windows
CODE: 3167-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Robinson Windows, LLC **13780 Benchmark Drive** **Farmers Branch, TX 75234**	**Series "200"** **Vinyl Fixed Window** Configuration: OOO Glazing: Insulating Glass (Annealed) Frame: W-2731mm (107.5") H-1816mm (71.5") Sidelite: W-794mm (31.25") H-1708mm (67.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22	**Class CW-PG45 2743 x 1829 (108 x 72)-FW** **Design Pressure: ±2640 Pa (±55 psf)** **Water Penetration Resistance Test: 580 Pa (12.11 psf)**

Product Tested By: Construction Consulting Laboratory
Report No: 26-147
Expiration Date: **February 28, 2030**

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com

NOTICE OF PRODUCT CERTIFICATION

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com