NFRC Product Certification Authorization Report

Manufacturer: Pacifica Vinyl Windows
Product Series: SS42/SS59/SS61 Picture Window
Simulation Lab: SATI
Initial Cert. Date: 11/30/2007

Street: 13181 IMPERIAL HWY
Product Type: FIXD
Sim. Report #: T2312.02-116-45 R0
Re-Certification Date: 07/01/2026

City/State/Zip: Whittier, CA 90605
Air Leakage:
Sim. Report Date: 12/16/2025
Revised Date: 06/25/2026

Print Date: 07/01/2026
Test Date: 03/19/2026
Expiration Date: 03/19/2031

CPD Number: PVW-M-1 | **IA: National Accreditation And Management Institute**

Status	Product Num.	Manufacturer Code	Frame/ Sash	Glaz Lyrs	Low-E (Surface)	Gap Width(s)	Spacer	Gap Fill	Grids	Dividers	Tint	U-Factor	SHGC	VT	Cond. Res
	00161-00001	"SS42: E366 / ARG90 / Clear (2mm/2mm) 3/4"" IG"	VY/NA	2	0.02(2)	0.563	P2-S	Fill 1: ARG (90)	N		CL	0.26	0.22	0.52	62
	00161-00002	"SS42: E366 / ARG90 / Clear (2mm/2mm) 3/4"" IG"	VY/NA	2	0.02(2)	0.563	P2-S	Fill 1: ARG (90)	G	0.75	CL	0.26	0.20	0.47	62
	00162-00001	"SS42: E366 / ARG90 / Clear (3mm/3mm) 3/4"" IG"	VY/NA	2	0.02(2)	0.500	P2-S	Fill 1: ARG (90)	N		CL	0.26	0.22	0.52	61
	00163-00001	"SS42: E366 / ARG90 / Clear (3mm/3mm) 3/4"" IG"	VY/NA	2	0.02(2)	0.500	P2-S	Fill 1: ARG (90)	G	0.75	CL	0.27	0.20	0.46	61
	00164-00001	"SS42: Grey / ARG90 / E366 (3mm/3mm) 3/4"" IG"	VY/NA	2	0.02(3)	0.500	P2-S	Fill 1: ARG (90)	N		CL	0.26	0.24	0.35	62
	00165-00001	"SS42: Grey / ARG90 / E366 (3mm/3mm) 3/4"" IG"	VY/NA	2	0.02(3)	0.500	P2-S	Fill 1: ARG (90)	G	0.75	CL	0.27	0.22	0.32	62
	00166-00001	"SS42: E366 / ARG90 / Clear (4mm/4mm) 3/4"" IG"	VY/NA	2	0.02(2)	0.437	P2-S	Fill 1: ARG (90)	N		CL	0.26	0.22	0.52	60
	00167-00001	"SS42: E366 / ARG90 / Clear (4mm/4mm) 3/4"" IG"	VY/NA	2	0.02(2)	0.437	P2-S	Fill 1: ARG (90)	G	0.75	CL	0.28	0.20	0.46	60
	00168-00001	"SS42: E366 / ARG90 / Clear (5mm/5mm) 3/4"" IG"	VY/NA	2	0.02(2)	0.375	P2-S	Fill 1: ARG (90)	N		CL	0.27	0.23	0.51	59
	00169-00001	"SS42: E366 / ARG90 / Clear (5mm/5mm) 3/4"" IG"	VY/NA	2	0.02(2)	0.375	P2-S	Fill 1: ARG (90)	G	0.75	CL	0.31	0.20	0.46	59
	00170-00001	"SS61: E366 / ARG90 / Clear (2mm/2mm) 3/4"" IG"	VY/NA	2	0.02(2)	0.563	P2-S	Fill 1: ARG (90)	N		CL	0.26	0.22	0.53	62
	00170-00002	"SS61: E366 / ARG90 / Clear (2mm/2mm) 3/4"" IG"	VY/NA	2	0.02(2)	0.563	P2-S	Fill 1: ARG (90)	G	0.75	CL	0.26	0.20	0.48	62
	00171-00001	"SS61: E366 / ARG90 / Clear (3mm/3mm) 3/4"" IG"	VY/NA	2	0.02(2)	0.500	P2-S	Fill 1: ARG (90)	N		CL	0.26	0.22	0.53	61
	00172-00001	"SS61: E366 / ARG90 / Clear (3mm/3mm) 3/4"" IG"	VY/NA	2	0.02(2)	0.500	P2-S	Fill 1: ARG (90)	G	0.75	CL	0.27	0.20	0.47	61
	00173-00001	"SS61: Grey / ARG90 / E366 (3mm/3mm) 3/4"" IG"	VY/NA	2	0.02(3)	0.500	P2-S	Fill 1: ARG (90)	N		CL	0.26	0.24	0.36	62
	00174-00001	"SS61: Grey / ARG90 / E366 (3mm/3mm) 3/4"" IG"	VY/NA	2	0.02(3)	0.500	P2-S	Fill 1: ARG (90)	G	0.75	CL	0.27	0.22	0.32	62

NFRC Product Certification Authorization Report

Manufacturer: Pacifica Vinyl Windows
Street: 13181 IMPERIAL HWY
City/State/Zip: Whittier, CA 90605
Print Date: 07/01/2026

Product Series: SS42/SS59/SS61 Picture Window
Product Type: FIXD
Air Leakage:

Simulation Lab: SATI
Sim. Report #: T2312.02-116-45 R0
Sim. Report Date: 12/16/2025
Test Date: 03/19/2026

Initial Cert. Date: 11/30/2007
Re-Certification Date: 07/01/2026
Revised Date: 06/25/2026
Expiration Date: 03/19/2031

CPD Number: PVW-M-1 **IA: National Accreditation And Management Institute**

Status	Product Num.	Manufacturer Code	Frame/ Sash	Glaz Lyrs	Low-E (Surface)	Gap Width(s)	Spacer	Gap Fill	Grids	Dividers	Tint	U-Factor	SHGC	VT	Cond. Res
	00175-00001	"SS61: E366 / ARG90 / Clear (4mm/4mm) 3/4"" IG"	VY/NA	2	0.02(2)	0.437	P2-S	Fill 1: ARG (90)	N		CL	0.26	0.23	0.52	60
	00176-00001	"SS61: E366 / ARG90 / Clear (4mm/4mm) 3/4"" IG"	VY/NA	2	0.02(2)	0.437	P2-S	Fill 1: ARG (90)	G	0.75	CL	0.28	0.21	0.47	60
	00177-00001	"SS61: E366 / ARG90 / Clear (5mm/5mm) 3/4"" IG"	VY/NA	2	0.02(2)	0.375	P2-S	Fill 1: ARG (90)	N		CL	0.27	0.23	0.52	59
	00178-00001	"SS61: E366 / ARG90 / Clear (5mm/5mm) 3/4"" IG"	VY/NA	2	0.02(2)	0.375	P2-S	Fill 1: ARG (90)	G	0.75	CL	0.31	0.21	0.46	59

Baseline Information

Test Lab	Test Date	Test Size	Tested U-Value	Standard U-Value	Test Report Number
TATF	**03/19/2026**	1200mm x 1499mm	0.288	0.285	T2313.02-301-46

Comments: N/A.

I hereby certify that all requirements for NFRC Certification Authorization have been met and that the above information is true and correct, to the best of my knowledge.

Authorized IA Signature: