NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO: NI017059.01
DATE: 08/06/2026
CERTIFICATION PROGRAM: Structural
COMPANY: Wincore
CODE: 1640-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Wincore Window Company, LLC **250 Staunton Turnpike** **Parkersburg, WV 26104**	**Series "9800"** **Vinyl Fixed Window** **(Fin & Retro Frame)** Configuration: O Glazing: IG-Ext. 3/16" Tempered Glass/Int. 1/8" Annealed Glass/0.090" SentryGlas Interlayer/1/8" Annealed Glass Frame: W-1422mm(56") H-2134mm(84") DLO: W-1311mm(51.63") H-2023mm(79.63")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 **ASTM E1886-19** **ASTM E1996-20**	**Class LC-PG60 1422 x 2134 (56 x 84)-FW** **Design Pressure: 2880 Pa (60 psf)** **Positive Design Pressure: 2880 Pa (60 psf)** **Negative Design Pressure: 3120 Pa (65 psf)** **Water Penetration Resistance Test Pressure: 575 Pa (12.00 psf)** **Missile Level D**

Product Tested By: Testing Evaluation Laboratories, Inc.
Report No: TEL 02804106/TEL 02804107
Expiration Date: **June 30, 2030**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com